



## CANADIAN LUMBER STANDARDS ACCREDITATION BOARD

#102-28 Deakin Street  
Ottawa, Ontario  
K2E 8B7 Canada

PHONE 613-482-2480  
E-MAIL info@clsab.ca  
WEB SITE www.clsab.ca

### MEMORANDUM

To: Canadian Building Associations and Officials, CLSAB Accredited Agencies, CLSAB Staff, Canadian Home Builders Association and ALSC

From: Chuck Dentelbeck, President & CEO, CLSAB

Date: March 24, 2022

Subject: Grade Stamp not recognized by the National Building Code of Canada

The grade stamp shown below was recently observed in Toronto.

This grade stamp is not from a CLSAB Accredited Agency and is not valid for structural use in Canada as:

- the National Building Code of Canada has no recognized design values for SPF-S lumber, and
- it does not contain a grading rule approved by the CLSAB such as the NLGA.

If you have questions about this memorandum, do not hesitate to contact me at [cdentelbeck@clsab.ca](mailto:cdentelbeck@clsab.ca) or 613-482-2480

### NOTE DE SERVICE

Destinataires: Autorités et Associations canadiennes du bâtiment, Agences Accréditées du CLSAB, Employés du CLSAB, et ALSC

De: Chuck Dentelbeck, Président et chef de la direction, CLSAB

Date: 24 mars 2022

Objet: Estampille de qualité non-reconnue par le Code national du bâtiment du Canada

L'estampille de qualité ci-dessous a récemment été observée à Toronto.

Cette estampe de qualité ne provient pas d'une agence accréditée CLSAB et n'est pas valide pour une utilisation structurale au Canada puisque:

- le Code national du bâtiment du Canada n'a pas de valeurs de conception reconnues pour le bois SPF-S, et
- elle ne contient pas de règle de classement approuvée par le CLSAB telle que la NLGA.

Si vous avez des questions sur cette note de service, n'hésitez pas à contacter François-Olivier Beaudoin à [fbeaudoin@clsab.ca](mailto:fbeaudoin@clsab.ca) ou au 613-482-2480

